



DEPARTMENT OF THE ARMY
SACRAMENTO DISTRICT, CORPS OF ENGINEERS
650 CAPITOL MALL
SACRAMENTO, CALIFORNIA 95814

REPLY TO
ATTENTION OF SPKED-T

23 October 1974

Mr. Kenneth M. James
Assistant City Engineer
City of Roseville
316 Vernon Street
Roseville, California 95678

Dear Mr. James:

This is in response to your 21 October 1974 letter requesting a flood hazard evaluation for a proposed subdivision site. The site is located adjacent to Coloma Way and Oakridge Drive.

137
11
→ Plate 11 in the report entitled, "Flood Plain Information, Dry Creek and Tributaries, Roseville, California," dated May 1973, shows that the Intermediate Regional and Standard Project Flood elevations would average 134.2 and 135.7 feet mean sea level, respectively at the location referenced above. Local drainage problems were not considered in our evaluation. A small portion of the site is in an area shown to be inundated by the occurrence of these floods (Plate 7). This is a ponded area however and therefore an encroachment would not obstruct passage of floodflows or significantly raise the water surface elevation.

Depending on the degree of protection required by the City of Roseville, finish grade elevations above the elevations stated above should be sufficient.

We are returning your copy of the proposed subdivision plan (inclosure 1) and existing topography (inclosure 2).

Sincerely yours,

George C. Weddell
for GEORGE C. WEDDELL
Chief, Engineering Division

2 Incl
As stated